



City of Santa Fe



ADDENDUM #1 November 4, 2015

**CIP #810A CERRILLOS ROAD RECONSTRUCTION, PHASE IIC PROJECT
Bid No. '16/13/QB**

Revisions and/or Clarifications to the Construction Plans and/or Project Manual & Construction Agreement:

1. Regarding storm drain pipe, Item Numbers 570XX1, 570XX2, and 570XX3, in addition to meeting the requirements of Special Provision F.9. Section 570 – Pipe Culverts, all pipe shall be storm drain culvert pipe with smooth walls meeting the requirements of NMDOT Standard Specifications for Highway and Bridge Construction, Section 570.2.1.5.
2. General Clarifications
 - a. The following documents will be made available for review on the City's website:
 1. "Pavement Section Design, Cerrillos Road, Santa Fe, New Mexico," November 3, 1999.
 2. Letter to Parsons Brinckerhoff Quade & Douglas with revised pavement recommendations, March 22, 2006.
 3. Letter to Parsons Brinckerhoff, re: Pavement Design Recommendations, February 12, 2014.
 4. "Initial Site Assessment, Cerrillos Road Reconstruction, Phase IIC, Camino Carlos Rey to Llano Street, Santa Fe, Santa Fe County, New Mexico," February 10, 2014.
 5. "Preliminary Site Investigation, Cerrillos Road Reconstruction, Phase IIC, Camino Carlos Rey to Llano Street, Santa Fe, Santa Fe County, New Mexico," May 2, 2014.
 - b. For information regarding the RFB, contact John Romero, City of Santa Fe Roadway and Trails Engineering Division, (505) 955-6638.
 - c. Regarding the Bid Bond, Bid Bonds are not released until after the project is awarded.
 - d. Plan Sheet 12-16, Detail H: The fiber optic lighting systems listed are no longer available. An LED lighting system with comparable performance characteristics will be considered as an approved equal. Bidders may contact John Tomlinson, (505) 764-1850, ext. 232 for more information.

- e. Question: The specs are conflicting regarding DBE requirements. Please clarify if this is or isn't a DBE project.
Answer: The DBE goal for the project is 0%. DBE reporting is required, and the Bidder must submit the DBE forms that are included in the Contract Document. Refer to the Bid Submittal requirements listed in the Bid Form, Section A.5.7.
- f. Question: The specs indicate that a bid security be submitted with bid. Please clarify if a bid bond is allowed in lieu of an actual check.
Answer: Either a certified check or a bid bond meeting the RFB requirements would be acceptable.
- g. Question: There are two bid bond forms in the specs, one City of Santa Fe form and the other on NMDOT. Please clarify which one is to be submitted with the bid.
Answer: For a bid bond, submit the City of Santa Fe Form in Section A.6. of the Contract Document.
- h. Question: Please provide a list of required documents to be submitted with bid.
Answer: The Bid Submittal requirements are listed in the Bid Form, Section A.5.7. The required Bid Submittal items listed under Notices to Contractor are included in Section H.4. Notice to the Contractors.
- i. Do bidders have to provide an extra copy of the bid in its entirety?
Answer: Yes.